



**Fire Prevention Office**  
 Allentown Fire Department  
 Office 610.437.7758  
 Fax 610.437.8781

**HAZARDOUS MATERIALS**  
**APPLICATION FOR ANNUAL PERMIT AS REQUIRED BY THE FIRE PREVENTION CODE**

Application is hereby made for a permit and/or certification to conduct, perform, engage in, or occupy any of the operations, processes, activities, or structures as provided for in Section 105 of the City of Allentown Fire Prevention Code. By this application, it is agreed that the occupancy will comply with all applicable ordinances and regulations. It is further agreed that said occupancy shall be open to inspection by the Allentown Fire Department.

**INSTRUCTIONS:** Make check or money order payable to the City of Allentown. **DO NOT SEND CASH.** Send the permit/inspection fee along with the completed application to **Allentown Fire Prevention, 435 Hamilton Street, Room 425, Allentown PA 18101. PERMITS ARE NOT TRANSFERABLE.** \*\*\* Permit and inspection fees not paid within thirty (30) days shall be subject to an added ten (10) percent late charge, to cover the added costs of collection.\*\*\*

**ASSOCIATED PERMIT TYPE AND PERMIT FEES ATTACHED.**

**COMPLETE ALL APPLICABLE INFORMATION**

Facility Name	
Name of Person Responsible	
Address	
City, State, Zip Code	
Business Phone Number	
Emergency Phone Number	
Business Email Address	
Name of Property Owner	
Phone Number of Property Owner	

Haz Mat Type	Permit Period	Permit Fee
Hazardous Production Material Facilities	1 Year	\$500.00
Hazardous Materials	1 Year	\$500.00
Pesticide Storage/Display	1 Year	\$175.00
Radioactive Material	1 Year	\$175.00
Cryogenic Fluids	1 Year	\$250.00

Please review and complete the checklist on the back of this page and return it with this completed application and payment.

**ALLENTOWN FIRE DEPARTMENT  
INSPECTION CHECKLIST  
HAZARDOUS MATERIAL SITE**

The International Fire Code (IFC) 2018 Edition has been adopted by the City of Allentown. Fire codes listed are not a comprehensive list and do not encompass all applicable codes. The noted code sections are commonly encountered and generally applicable for this inspection type.

In an effort to streamline the inspection process for your facility and the inspecting Fire Marshal we have included some guidelines specific to your business to help you prepare before the inspection to ensure you receive a passing inspection and **avoid multiple visits for any violations**. [Please use the checklist below before returning the application and payment.](#)

	Call out names up to date.
	Does AFD have list of current facility resources?
	Are new, nearby facilities at risk?
	<b>IFC 5001.5.2</b> -Tier II Report or list of chemicals.
	<b>IFC 407.2 &amp; 407.5</b> -Material safety data sheets or inventory.
	New hazards or chemicals.
	<b>IFC 404.2.1</b> -Maps up to date
	<b>IFC 603</b> -Heating System Serviced per guidelines. Gas-2 Yr., Oil 1 Yr. Maximum Intervals
	<b>IFC 705</b> -Fire doors operable and tested.
	Required exits accessible during occupancy.
	<b>IFC 1013 &amp; 1013.4</b> -Exits marked with approved exit signs.
	<b>IFC 1008 &amp; 1025</b> -Main rooms, exit paths and discharge areas lighted with artificial lighting with battery backup.
	<b>IFC 604</b> -Occupancy free from obvious electrical/extension cord hazards.
	<b>IFC 901.6 &amp; 907.8</b> -Manual alarm, fire detection and fire sprinklers operable. Test documentation required.
	<b>IFC 912</b> -Fire department connection accessible and capped.
	<b>IFC 901.6 &amp; 906.2</b> -Fire extinguishers installed and tested per code.
	Construction type.
	Roof type.
	Precautions for incoming personnel displayed.
	<b>IFC 505.1</b> . Address visible from the street.

***Return with yearly permit payment to the Fire Prevention Office***